

DECLARATION OF PERFORMANCE

Date of issue: 03/02/2020

No. 1796-CPR-0014-2020/3

1	Unique identification code of the product-type: <h3 style="text-align: center;">Smoke extraction duct section model: PROMADUCT®-500</h3>		
2	Intended uses smoke extraction ducts sections are intended to use in smoke and heat control systems. They are intended for single fire compartment, in 4-sided and 3-sided horizontal configurations with 20mm of Promatect-L500.		
3	Name and contact address of the manufacturer: Promat Techniczna Ochrona Przeciwpożarowa Sp. z o.o. ul. Przeclawska 8 03-879 Warszawa Poland www.promatop.pl		
4	Authorised representative: N/A		
5	System or systems of Assessment and Verification of Constancy of Performance (AVCP): System 1		
6a	The construction product is covered by a harmonised standard (hEN) – EN 12101-7		
6b	Notified product certification body: No. 1796 Fire Research Centre of the Fire and Rescue Department of the Republika of Lithuania Certificate of Constancy of Performance: 1796-CPR-0014		
7	Declared performance		
	Essential characteristics	AVCP systems	Performance
			Harmonised technical specification
	BWR1: Mechanical resistance and stability: not applicable.		
	BWR2: Safety in the case of fire:		
	Resistance to fire:	1	E ₆₀₀ 120 (ho) S1500single
			EN 12101-7 EN 13501-4

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

The reader of this document is invited to visit the website "www.promatop.pl" to review the latest version of this DoP.

The Safety Data Sheets (SDS) of components of PROMADUCT®-500 are available on request.

Signed for and on behalf of the manufacturer by:

Name: Elżbieta Mazur
Function: Technical Director, Promat Techniczna Ochrona Przeciwpożarowa Sp. z o.o..

Warsaw, 03/02/2020.

Signature:

Promat
Techniczna Ochrona Przeciwpożarowa Sp. z o.o.
ul. Przeclawska 8, 03-879 Warszawa
Dyrektor Techniczny

mgr inż. Elżbieta Mazur